

ADDENDUM #3

Issued: April 17, 2018
Closing Date: Wednesday April 25, 2018
@2:00:00pm Local Time

The following are a list of questions received from prospective bidders as well as responses.

- 1) Question: Can you tell us what kind of pipe material is acceptable? HDPE, fusible, PVC, Terra Brute, Cobra Lock?

Revised our answer to question #10 from this morning's addendum.

Response: Fusible pipe (PVC), Fusible Brute or approved equivalent conforming to AWWA C-900, Class 235, DR18 water pipe in accordance with Section 6.0 – SPECIAL PROVISIONS – “Item No. 4 – Various Size Watermain Installation by Horizontal Direction Drilling (HDD)”.

No HDPE pipe will be accepted.

Tender closing date moved to Wednesday
(April 25th) at 2:00pm.