



Clarence-Rockland

**CORPORATION
de la Cité de/ of the City of
CLARENCE-ROCKLAND**

ADDENDUM #1

6/29/2020 14:41

F18-INF-2020-013

Tender Number

New Courtyard Construction

Request for Proposals Issued On:
18-Jun

Proposal Submission Deadline: 2:00:00pm Local Time in Clarence-Rockland Ontario, Canada on
July 13, 2020

THE INFORMATION CONTAINED IN THIS DOCUMENT IS TIME SENSITIVE

Please note: This addendum is to be considered part of the above noted Request for Proposal/Tender as though included with the original version.
This addendum does not affect the closing date/time: Bidders should acknowledge receipt of all Addendum / Addenda by inserting in the space provided on the Bid Submission Form, the numbers of all Addendum / Addenda received during the bidding period.

QUESTION REQUESTING CLARIFICATION

The following questions were received:

1	Question:	We need the T/G and invert for the 1200 mm x 1200 mm DIMH on this project.
	Reply:	The T/G and invert for the 1200 mm x 1200 mm DIMH is provide on the Grading Plan: T/G = 54.80 and INV = 53.85.

END OF ADDENDUM #1